

NOTE: You cannot save the DATA you entered on this form, you must print a copy and FAX it or MAIL it!



TECHNICAL STANDARDS & SAFETY AUTHORITY
14th Floor, Centre Tower
3300 Bloor Street West
Toronto, Ontario
Canada M8X 2X4

Show facsimile of manufacturer's logo or trademark, as it will appear on the fitting, in the space below



STATUTORY DECLARATION Registration of Fittings

I, Tim Narel, Director of Engineering & Quality Assurance
(Name and Position, e.g. President, Plant Manager, Chief Engineer)

of Milwaukee Valve Company
(Name of Manufacturer)

Located at 16550 West Stratton Drive, New Berlin, Wisconsin 53151 USA 262-432-2700 262-432-2701
(Plant Address) (Telephone No.) (Fax No.)

do solemnly declare that the fittings listed hereunder, which are subject to the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, comply with all of the requirements of _____
(Title of recognized North American Standard)

which specifies the dimensions, materials of construction, pressure/temperature ratings, identification marking the fittings and service;

or are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with _____ as supported by the attached data which identifies the dimensions, material of construction, pressure/temperature ratings and the basis for such ratings, the marking of the fitting for identification and service.

I further declare that the manufacture of these fittings is controlled by a quality system meeting the requirements of ISO 9001-2008 ANSI/ISO/ASQ which has been verified by the following authority, LRQA

The items covered by this declaration, for which I seek registration, are category category C, line valve type fittings. In support of this application, the following information and/or test data are attached as follows:

(drawings, calculations, test reports, etc.)



declared before me at Milwaukee Valve Company Inc in the County of Waukesha of State of Wisconsin

the 27th day of August AD 20 14.

Commissioner for Oaths:
Patricia S. Krueger
(Printed name)

Patricia Skruoger
(Signature) My Commission expires June 29, 2015

[Signature]
(Signature of Declarer)

FOR OFFICE USE ONLY


To the best of my knowledge and belief, the application meets the requirements of the **Technical Standards and Safety Act**, Boilers and Pressure Vessels Regulation, and CSA Standard B51 and is accepted for registration in Category C

CRN: 0C8213.5ADDG

Registered by: Liliana Constantinescu

Dated: Sept. 23, 2014

NOTE: This registration expires on: JAN 31, 2023



Scope of registration: See attached stamped document. [Signature]

Summary of Products for Milwaukee Valve Company Submitted for CRN (Ontario only)

The tables below summarize the Milwaukee Valve Company products, which are being submitted to TSSA for Ontario Registration as an addition to existing 0C8213.5R3

Also note that Hammond Valve is a brand name sold under Milwaukee Valve Company's corporate umbrella. In some cases we have distinct Hammond figure numbers for products, which are identical to Milwaukee Valve Company's product offerings. Where Milwaukee figure numbers are provided with corresponding Hammond Brand Figure numbers, these products are identical in nature, which include the body and other structural components, the only variations to the products could be the handle and/or identification nameplate.

Bronze Valve Additions to 0C8213.5R3					
Valve Figure No. Milwaukee Brand	Milwaukee Catalog/Bulletin No.	Valve Figure No. Hammond Brand	Valve Type	Certification/ Approvals	Design Standards
1509/1509T (3/8" - 3")	1509/1509T data sheet no. I-38	IB912 (3/8" - 3")	Swing Check, 125 SWP/200 WOG, bronze, sweat ends		MSS SP-80

CRN # 0C8213.5R3 includes the Milwaukee 509/509T SWING CHECK VALVE with NPT ends but does not currently include the 1509/1509T SWING CHECK VALVE with SWEAT ends. Both models are to the MSS SP-80 standard and satisfy the same Pressure-Temperature rating. Except for the area of the end connections, the valves, including wall thickness and the design are the same. The end connections of the 1509/1509T meet the requirements of ASME B16.22 Table 3, Dimensions of Solder End Joints

Bronze Valve Additions to 0C8213.5R3					
Valve Figure No. Milwaukee Brand	Milwaukee Catalog/Bulletin No.	Valve Figure No. Hammond Brand	Valve Type	Certification/ Approvals	Design Standards
1590T (1/2" - 3")	1590T data sheet no. I-26	IB423 (1/2" - 3")	Globe, 150SWP/300 WOG, bronze, sweat ends		MSS SP-80

CRN # 0C8213.5R3 includes the Milwaukee 590T GLOBE VALVE with NPT ends but does not currently include the 1590T GLOBE VALVE with SWEAT ends. Both models are to the MSS SP-80 standard and satisfy the same Pressure-Temperature rating. Except for the area of the end connections, the valves, including wall thickness and the design are the same. The end connections of the 1509/1509T meet the requirements of ASME B16.22 Table 3, Dimensions of Solder End Joints

